



Fire safety

Fire safety risk assessment

Fire safety risk assessment form is carried out in each area of the setting by a competent person using the five steps to fire safety risk assessment as follows:

1. Identify fire hazards
 - Sources of ignition.
 - Sources of fuel.
 - Sources of oxygen (including oxygen tanks for disabled children).
2. Identify people at risk
 - People in and around the premises.
 - People especially at risk including less ambulant disabled children or those using specialised equipment, such as splints, standing frames.
3. Evaluate, remove, reduce and protect from the risk
 - Evaluate the risk of the fire occurring.
 - Evaluate the risk to people from a fire starting on the premises.
 - Remove and reduce the hazards that may cause a fire.
 - Remove and reduce the risks to people from a fire.
4. Record, plan, inform, instruct, train
 - Record significant findings and action taken.
 - Prepare an emergency plan.
 - Inform and instruct relevant people; inform and co-operate with others.
 - Provide training.
5. Review
 - Keep assessment under review and revise when necessary.

The fire safety risk assessment focuses on the following for each area:

- Electrical plugs, wires, sockets.
- Electrical items.
- Cookers.

- Flammable materials, including furniture, furnishings, paper etc.
- Flammable chemicals (which are also covered in COSHH).
- Means of escape.
- Any other, as identified.

Fire safety precautions include:

- All electrical equipment is checked by a qualified electrician annually.
- Any faulty electrical equipment is taken out of use and recorded as such or condemned (whichever is necessary).
- Water and electrical items do not come into contact; staff do not touch electrical items with wet hands.
- All fire safety equipment is checked annually.
- If matches are used in the kitchen, they are kept in a drawer.

Fire Drills

- Fire Drills (to include emergency evacuation procedures and lock down) are held at least termly.
- Drills are recorded, including:
 - date of drill
 - staff involved and numbers of children
 - how long it took to evacuate
 - any reason for a delay in achieving the target time and how this will be remedied

Fire precautions

- Fire exit signs are the green 'running man' signs and are in place and clearly visible.
- Fire exits by doors are those that show a green light at night.
- Fire doors are not locked during normal working hours.
- Fire evacuation notices say where the assembly point is.
- Fire alarms are in place and tested monthly, and where necessary supplemented with visual warnings. This is recorded.
- A fire blanket is in place in the kitchen (and any other location where there is a cooker).
- Fire extinguishers are in place and are appropriate